



NO LEAD



**No Lead
CNL-1000 Series
Yard Hydrant**

**Leave This
With
Homeowner**

CAUTION: Use Wrench On Valve Body and Fitting ONLY!

Do **NOT** use wrench on this stand pipe! Additional tightening or loosening will change adjustment of hydrant and could restrict water flow or may make the hydrant inoperative.

CAUTION: If the hose is attached to nozzle of hydrant when hydrant is shut off, back siphoning can occur if end of hose is left in container of liquid. The end of hose must be left open to the air so hydrant can drain back. Under **NO** circumstances should Merrill Yard Hydrants drain back into well or drinking water supply!

Merrill Mfg. disclaims all liability of any kind and voids the hydrant warranty for installations of this product where it can or could drain back into a drinking water supply.

Consult with factory if system pressure is over 100 psi before installation of this product.

NOTE: Questions - Help With Installation - Problems in the Field
CALL (712)-732-2760

Do **NOT** Dig Up Hydrant - Call MERRILL First



WARNING: This product meets Federal USA Drinking Water requirements but has not been specifically tested or approved as no-lead in the State of California.

www.merrillmfg.com

Form No. 156.3