

## AC-913 Instructions

Air Conditioners – Central and Portable: For initial application, place two (2) or more tablets in the condensate drain tray for each ton (12,000 BTU) or air conditioning. Position the tablet(s) at a point furthest from the drain to assure complete treatment. Additional applications should be done monthly at the rate of one tablet per ton.

Dehumidifiers – Console and Central: Drop two (2) to four (4) tablets in the water tank. Repeat application each time tank is emptied. Periodically rinse tank and wipe clean.

Humidifiers – Console and Central: Drop two (2) to four (4) tablets in the reservoir. Repeat every four to six weeks. Periodically check for accumulations and adjust dosage as necessary depending upon humidification levels and temperature.

Refrigerators: Drop one tablet into the condensate drain tray. Position the tablet so that the condensing water drips over it. Rinse and wipe pan after emptying. Repeat application.