




Smoke and Smoke + Carbon Monoxide Alarm Adapter

Model 20-9003

Quick Connect wiring adapter for connecting to existing Kidde/Firex wire harnesses.

- Designed for use with Kidde hardwired alarms.
- Not compatible with other manufacturer's products.

10-YEAR LIMITED WARRANTY



Images are representative only.
Actual product may vary slightly.

Description

This adapter can be used to quickly connect Kidde alarms with the existing wiring harness without having to re-wire or replace the wiring harness:

i12020, i12020A, i12040, i12040A, i12060, i12060A, i12080, i12080A, i4618A, i4618AC, KN-SMFM-I, RF-SM-ACDC, PE120, P12040, P12000, P12010, KN-COSM-I, KN-COSM-IB, KN-COSM-IBA, KN-COPE-I, KN-COB-IC, SL177i, SLED177i, HD135F, SM120X, CO120X, i12010S, i12010SCO, P4010ACSCO, P4010ACSCO-W, P4010LACS-W, P4010ACS, P4010ACS-W, P4010ACLEDS, P4010ACLEDS-2, P4010ACLEDS-CO, P4010ACLEDS-CO-2, 3050-VAS10-A, 3050-VAS10-A, P4010ACS-WF, P4010ACSAQ-WF, P4010ACSCO-WF, P4010ACSCOQ-WF. See Kidde.com for complete list.

⚠ WARNING: Turn off AC power before attempting to connect wire harnesses or adapters. This smoke alarm adapter allows the installation of new Kidde alarms to existing "legacy" Kidde wiring harnesses. When using this adapter, the power harness supplied with your new Kidde alarm is not used. Connect the 20-9003 adapter to the legacy (existing) Kidde wiring harness and confirm it snaps into position. Give a small tug to make sure the adapter is snapped into place. Then insert the opposite end of the adapter into the back of the new unit. After installation, turn on AC power and be sure that the AC power indicator is operating and test all your alarms following the instructions supplied by the alarm manufacturer for your specific alarm model. If the alarms are interconnected push the test button on each alarm and verify that all the interconnected alarms sound when any alarm is activated. The interconnect system should not exceed the NFPA interconnect limit of 12 smoke alarms. SEE USER GUIDE FOR COMPLETE INSTRUCTIONS.



FIGURE 1:
Compatible existing
Kidde harnesses




FIGURE 2:
Adapter connecting
to the old harness



Ordering Information

Ordering Number	UPC	GTIN	Pack Config	Pack Qty	Case Dimensions (w x d x h inches)	Case Weight (lbs)	Cartons/Pallet
21032239	047871322398	10047871322395	Box	Tray/Lid (6 Units)	5.14 x 10.81 x 3.09	3.1	2016



1016 Corporate Park Drive, Mebane, NC 27302
1-800-880-6788 www.Kidde.com

A Carrier Company
©2023 Carrier. All Rights Reserved.
All trademarks and service marks referred herein
are property of their respective owners.

