

Inspection, Repair, and Replacement of CSST

Minimum Inspection Requirements Checklist

All installations shall be inspected by the authority having jurisdiction in accordance with state and local mechanical, electric, and/or plumbing codes, or in the absence of such codes, the National Fuel Gas Code (NFPA 54/ANSI Z 223.1), the International Fuel Gas Code (IFGC), the National Electric Code (NFPA 70), and/or the Uniform Plumbing Code (UPC), as applicable.

- ☐ Installer has HOME-FLEX or VPC Alpha-FLEX Qualified Installer Card
- ☐ Inspection and pressure test completed at rough-in
- ☐ Only fixed appliances are directly connected to the HOME-FLEX system
- ☐ Connections to moveable appliances are made with HOME-FLEX Flexible Appliance Connectors, or similar approved devices
- ☐ System properly sized to deliver pressure required for all appliances
- ☐ Regulator, if required, is installed in an accessible location with a shut-off valve mounted ahead of it
- ☐ If routed underground or through masonry, HOME-FLEX tubing is properly sleeved
- ☐ Striker plate protection in place where required
- ☐ HOME-FLEX tubing is supported at proper interval
- ☐ No damaged tubing dents or defects
- ☐ Direct bond to the electrical service grounding electrode system

HOME-FLEX[®]



HOME-FLEX.com