



Galvanized Pipe & Nipple

General Assembly of Pressurized Threaded Pipe and Fittings

Galvanized pipe is made of schedule 40 black steel dipped in a hot zinc bath. It is suitable for air, water, and decor applications. Galvanization is done according to ASTM A153 specifications.

Instructions

1. Turn off water or air supply before removing old pipes.
2. Before installation, check all male and female components for any damage, debris, or excess threading oil. Clean or replace parts as necessary.
3. Apply pipe dope or thread seal tape to pipe and fittings. Follow manufacturer's instructions for correct application.
4. Assemble the pipe and fittings. Hand-tighten as much as possible, then tighten an additional 4 to 5 turns with a pipe wrench.
5. Check for leaks.