

HOME-FLEX[®]

UNDERGROUND

System Design and Installation Manual



**Know what's below.
Call 811 before you dig.**

Suggested Tools for Installation of HOME-FLEX Underground®



Ratcheting Pipe Cutter

Use to cut HOME-FLEX Underground® MDPE pipe to desired length.



2x Large Groove Joint or
PVC Fitting Pliers

Use to tighten the fitting nut against the fitting flange.



Gloves



Eye Protection

For technical support call: **661-257-3923** or email: **info@homeflex.com**

HOME-FLEX Underground®

System Design and Installation Manual

Chapter 1: Introduction

| | |
|--|---|
| 1.1 Introduction..... | 1 |
| 1.2 User Warnings..... | 2 |
| 1.3 Limitations of Manual..... | 3 |
| 1.4 Applicable Codes and Standards..... | 3 |
| 1.5 Prohibited Installation Practices..... | 3 |

Chapter 2: Description of System Components

| | |
|----------------------------------|---|
| 2.1 Gas Pipe..... | 4 |
| 2.2 Fittings..... | 5 |
| 2.3 Conversion Fittings..... | 8 |
| 2.4 Transition Fittings..... | 9 |
| 2.5 Anodeless Service Riser..... | 9 |

Chapter 3: System Configuration and Sizing

| | |
|---|----|
| 3.1 Configuration..... | 10 |
| 3.2 Reference Data for Proper Sizing..... | 11 |
| 3.3 Sizing Methods and Examples..... | 11 |
| Low Pressure (Less than or equal to 2.0 PSI Natural Gas)..... | 11 |
| Low Pressure (Less than or equal to 2.0 PSI) LP Gas..... | 11 |
| Elevated Pressure (10 PSI) LP Gas..... | 12 |

Chapter 4: Installation Practices

| | |
|--|----|
| 4.1 Installation Practices and Guidelines..... | 14 |
| 4.2 Trenching..... | 15 |
| 4.3 Fitting Assembly Overview..... | 16 |
| 4.4 Pressure and Leak Testing..... | 18 |
| Troubleshooting Fitting Assembly and Correcting Leaks..... | 18 |

Chapter 5: Sizing/Capacity Tables

| | |
|---|----|
| 5.1 Fitting Adjustment Values for Determining Run Length..... | 20 |
| 5.2 Natural Gas Sizing Tables..... | 21 |
| Less than 2 PSI with 0.3 in. w.c. drop..... | 21 |
| Less than 2 PSI with 0.5 in. w.c. drop..... | 22 |
| 2 PSI with 1 PSI drop..... | 23 |
| 5.3 Liquid Petroleum (LP) Gas Sizing Tables..... | 24 |
| Less than 11 in. w.c. with 0.5 in. w.c. drop..... | 24 |
| 2 PSI with 1 PSI drop..... | 25 |
| 10 PSI with 1 PSI drop..... | 26 |

Chapter 1: Introduction

This side of the HOME-FLEX® manual applies to HOME-FLEX Underground® pipe and its associated plastic fittings. **HOME-FLEX® CSST and HOME-FLEX Underground® are two different systems with different uses and installation requirements. The tubing and fittings are not interchangeable.**

HOME-FLEX Underground pipe is made of a yellow poly plastic all the way through. It has a smooth outside wall and a smooth inside wall. The fittings are made of plastic. HOME-FLEX Underground gas pipe and fittings are for use with natural gas and LP (propane) gas. This poly gas pipe must be installed outdoors and underground only. The plastic pipe may never be used above ground, in a building or under a building.

1.1 Introduction

HOME-FLEX® CSST and HOME-FLEX Underground® are two different systems with different uses and installation requirements. The tubing and fittings are not interchangeable.

An installer must be aware of all of the HOME-FLEX Underground installation instructions and knowledgeable in all applicable plumbing and building codes. HOME-FLEX Underground installation practices and guidelines are found in this manual, packaged with each HOME-FLEX Underground fitting and on the HOME-FLEX Underground website, homeflexunderground.com.

HOME-FLEX Underground gas pipe is Medium Density Polyethylene (MDPE) gas pipe. It is also referred to as PE or poly gas pipe. It is made in accordance with the ASTM D2513 standard. It is approved for direct burial into the ground in accordance with the local plumbing code at the installation location. It is flexible, lightweight, easy to work with and easy to install. Unlike metallic gas pipe, it will not rust or corrode when properly installed. HOME-FLEX Underground PE gas pipe is iron pipe size (IPS). It is approved for use with Natural Gas or LP gas. It is never to be installed in a building or house. It is never to be installed under a building or house. It is never to be installed above grade.

HOME-FLEX Underground fittings are approved for direct burial. They can be installed without the need for special tools or equipment. HOME-FLEX Underground fittings are constructed of plastic and they are a compression type fitting. Once installed, they can be removed and reinstalled as long as they have not been damaged in any way.

HOME-FLEX Underground couplers, elbows and tees are approved to the ASTM F1924 standard. They may be used with any brand of properly sized ASTM D2513 Yellow Poly Gas Pipe. These fittings are sized for IPS Poly Gas Pipe in ½" (SDR 9.3), ¾" (SDR 11), 1" (SDR 11), 1¼" (SDR 11), 1½" (SDR 11) and 2" (SDR 11) diameters. They are approved for use with Natural Gas or LP Gas. You must verify that your local jurisdiction allows the use of F1924 fittings prior to performing your installation. The Transition Fittings and Risers are approved to ASTM F1973. HOME-FLEX Underground gas pipe is approved ASTM D2513.

The HOME-FLEX Underground® Gas Distribution System must be installed by a trained installer who meets the following criteria:

1. **Installer must meet all qualifications required by the state and/or local administrative authority administering the provisions of the code where the gas piping is installed.**
2. **An installer must also be informed in the use of HOME-FLEX Underground® Gas Distribution System. Information regarding Valencia Pipe Company's HOME-FLEX Underground® system can be obtained by reading the HOME-FLEX Underground® Gas Distribution System Installation/Training Guide and registering with Valencia Pipe Company. To obtain a Registered Installer Card, register online at homeflexunderground.com. In submitting the online registration, you are affirming that you understand all aspects of the installation requirements and local**

Introduction

plumbing, mechanical, electrical, and/ or applicable building codes. If you do not understand all requirements and local codes, contact a licensed professional plumber.

The installation shall be made in accordance with local codes, or, in the absence of local codes, in accordance with the National Fuel Gas Code (ANSI Z223.1 / NFPA 54); the Liquefied Petroleum Gas Code (NFPA 58); Natural Gas and Propane Installation Code (CSA B149.1); the International Fuel Gas Code (IFGC), or the Uniform Plumbing Code (UPC). In addition, ASTM D2774 (Standard Practice for Underground Installation of Thermoplastic Pressure Piping) and the installation instructions as prescribed by Valencia Pipe Company must be followed.

Special attention must be given to the proper design, installation, testing and use of the gas piping. Sound engineering principles and practices must be exercised as well as diligent adherence to proper installation procedures. All installed systems must pass customary installation inspections by the administrative authority having jurisdiction prior to being placed in service.

1.2 User Warnings

- △ *When a conflict exists between this guide and local code requirements; the local codes shall take precedence.*
- △ *Improper installation or operation of the gas piping system may result in fire, explosion or asphyxiation.*
- △ *Only components provided or specified by Valencia Pipe Company as part of the HOME-FLEX Underground® Gas Distribution System are to be used in the installation.*
- △ *The installation instructions and practices outlined in this training guide only apply to the use of HOME-FLEX Underground® Gas Distribution System. Valencia Pipe Company assumes no responsibility for installations made with other manufacturer's gas piping systems.*



**WARNING! THIS PRODUCT IS FOR
UNDERGROUND USE ONLY.**



Always call 811 prior to digging.



**Know what's below.
Call 811 before you dig.**



WARNING!

Improper installation or operation of the system may result in fire, explosion or asphyxiation. Only the components provided or specified by Valencia Pipe Company, for use as part of the fuel gas system are to be used in the installation.

1.3 Limitations of Manual

While every effort has been made to prepare this document in accordance with all regional model codes in effect at its printing, Valencia Pipe Company cannot guarantee that the local administrative authority will accept this. It is the ultimate responsibility of the installer to determine the suitability and acceptance of any building components including gas piping. Valencia Pipe Company, manufacturer of HOME-FLEX Underground® Gas Distribution System, assumes no responsibility for labor or material for installations made without prior determination of local code authority acceptance.

1.4 Applicable Codes and Standards

- NFPA 54/ANSI Z223.1 - National Fuel Gas Code
- NFPA 58 - Liquefied Petroleum Gas Code
- ICC - International Fuel Gas Code
- IAPMO - Uniform Plumbing Code



Items marked with the UPC logo are IAPMO certified for the United States.

1.5 Prohibited Installation Practices

- ⚠ **DO NOT** install HOME-FLEX Underground Products in above ground installations.
- ⚠ **DO NOT** install HOME-FLEX Underground Products inside buildings.
- ⚠ **DO NOT** install HOME-FLEX Underground Products under buildings.
- ⚠ **DO NOT** encase HOME-FLEX Underground Products inside concrete.
- ⚠ **DO NOT** connect HOME-FLEX Underground fittings to poly gas pipes other than the specified size (including SDR) marked on the fitting.



Valencia Pipe Company

28305 Livingston Ave Phone: 661-257-4403

Valencia CA 91355

Fax: 661-257-3928

Email: info@homeflex.com

www.homeflexunderground.com

Copyright © 2020 Valencia Pipe Company. HOME-FLEX Underground® and the VPC logo are registered trademarks of Valencia Pipe Company, Inc. All rights reserved. The 811 logo is a registered trademark of the CGA. 1901/C6

Chapter 2: Description of System Components

2.1 Gas Pipe

Application Information

For use in direct burial Natural Gas and Liquefied Petroleum (LP) Gas applications with Polyethylene (PE) gas pipelines.


Technical Data


| Materials | |
|--|--|
| Pipe: Polyethylene (PE 2406/2708) | |
| Pressure Ratings | Temperature Ratings |
| Max Operating Pressure: 80 PSIG | Operating Temperature Range: 0°F - 140°F |
| Codes | Standards |
| NFPA 54/ANSI Z223.1 NFPA 58 International Fuel Gas Code Uniform Plumbing Code | ASTM D2513 NSF/ANSI 14 Certified |

Dimensional Information

| Part Series | Size (IPS) | SDR | Dimensions (in) | | | Min Bend Radius |
|-------------|------------|-----|-----------------|------------|----------------|-----------------|
| | | | Av. OD | Approx. ID | Min Wall Thick | |
| 19-0593XXX | ½" | 9.3 | 0.840 | 0.660 | 0.090 | 17.00" |
| 19-0711XXX | ¾" | 11 | 1.050 | 0.860 | 0.095 | 26.25" |
| 19-1011XXX | 1" | 11 | 1.315 | 1.075 | 0.120 | 30.00" |
| 19-1211XXX | 1¼" | 11 | 1.660 | 1.358 | 0.151 | 41.50" |
| 19-1511XXX | 1½" | 11 | 1.900 | 1.554 | 0.173 | 47.50" |
| 19-2011XXX | 2" | 11 | 2.375 | 1.943 | 0.216 | 59.40" |

Part Number Listing

| | Part No. | Size (IPS) | SDR | Length |
|---|------------|------------|-----|--------|
|  | 19-0593100 | ½" | 9.3 | 100' |
| | 19-0593250 | ½" | 9.3 | 250' |
| | 19-0593500 | ½" | 9.3 | 500' |
| | 19-0711100 | ¾" | 11 | 100' |
| | 19-0711250 | ¾" | 11 | 250' |
| | 19-0711500 | ¾" | 11 | 500' |
| | 19-1011100 | 1" | 11 | 100' |
| | 19-1011250 | 1" | 11 | 250' |
| | 19-1011500 | 1" | 11 | 500' |

| | Part No. | Size (IPS) | SDR | Length |
|---|------------|------------|-----|--------|
|  | 19-1211100 | 1¼" | 11 | 100' |
| | 19-1211250 | 1¼" | 11 | 250' |
| | 19-1211500 | 1¼" | 11 | 500' |
| | 19-1511100 | 1½" | 11 | 100' |
| | 19-1511250 | 1½" | 11 | 250' |
| | 19-1511500 | 1½" | 11 | 500' |
| | 19-2011100 | 2" | 11 | 100' |
| | 19-2011250 | 2" | 11 | 250' |
| | 19-2011500 | 2" | 11 | 500' |

Check homeflexunderground.com for up-to-date product listings.

2.2 Fittings

Application Information


Gas compression fittings for use in Natural Gas and Liquefied Petroleum (LP) Gas applications with Polyethylene (PE) gas pipelines.






Technical Data

| Materials | |
|---|--|
| Nut and Main Body: Polypropylene (PP) Spacer: Nylon | O-Ring: Nitrile Grip Ring & Stiffener: Acetal |
| Pressure Ratings | Temperature Ratings |
| Max Operating Pressure: 125 PSIG | Operating Temperature Range: -20°F - 180°F |
| Codes | Standards |
| NFPA 54/ANSI Z223.1 International Fuel Gas Code Uniform Plumbing Code | ASTM F1924 ASTM D2513 |


Part Number Listing

| | Part No. | Description | SDR |
|---|------------|----------------------------------|-----|
|  | 18-429-005 | ½" x ½" Coupling Fitting | 9.3 |
| | 18-429-101 | ½" CTS x ½" IPS Coupling Fitting | 9.3 |
| | 18-429-007 | ¾" x ¾" Coupling Fitting | 11 |
| | 18-429-010 | 1" x 1" Coupling Fitting | 11 |

| | Part No. | Description | SDR |
|---|---------------|--------------------------------------|-----|
|  | 18-429-012-10 | 1¼" x 1¼" Coupling Fitting (SDR 10) | 10 |
| | 18-429-012 | 1¼" x 1¼" Coupling Fitting | 11 |
| | 18-429-015 | 1½" x 1½" Coupling Fitting | 11 |
| | 18-429-020 | 2" x 2" Coupling Fitting | 11 |
|  | 18-406-005 | ½" x ½" Elbow Fitting | 9.3 |
| | 18-406-007 | ¾" x ¾" Elbow Fitting | 11 |
| | 18-406-010 | 1" x 1" Elbow Fitting | 11 |
| | 18-406-012-10 | 1¼" x 1¼" Elbow Fitting (SDR 10) | 10 |
| | 18-406-012 | 1¼" x 1¼" Elbow Fitting | 11 |
| | 18-406-015 | 1½" x 1½" Elbow Fitting | 11 |
| | 18-406-020 | 2" x 2" Elbow Fitting | 11 |
|  | 18-401-005 | ½" x ½" x ½" Tee Fitting | 9.3 |
| | 18-401-007 | ¾" x ¾" x ¾" Tee Fitting | 11 |
| | 18-401-010 | 1" x 1" x 1" Tee Fitting | 11 |
| | 18-401-012-10 | 1¼" x 1¼" x 1¼" Tee Fitting (SDR 10) | 10 |
| | 18-401-012 | 1¼" x 1¼" x 1¼" Tee Fitting | 11 |
| | 18-401-015 | 1½" x 1½" x 1½" Tee Fitting | 11 |
| | 18-401-020 | 2" x 2" x 2" Tee Fitting | 11 |

Check homeflexunderground.com for up-to-date product listings.

Coupling Fitting Dimensional Information




| Part Number | Size (IPS) | SDR | Dimensions (in) | | | Weight (lbs) |
|---------------|------------|-----|-----------------|------|------|--------------|
| | | | S | D | L | |
| 18-429-005 | ½" | 9.3 | 0.39 | 1.81 | 4.37 | 0.18 |
| 18-429-007 | ¾" | 11 | 0.43 | 2.13 | 4.69 | 0.29 |
| 18-429-010 | 1" | 11 | 0.55 | 2.68 | 5.75 | 0.46 |
| 18-429-012-10 | 1¼" | 10 | 0.71 | 3.23 | 7.17 | 0.93 |
| 18-429-012 | 1¼" | 11 | 0.71 | 3.23 | 7.17 | 0.93 |

| Part Number | Size (IPS) | SDR | Dimensions (in) | | | Weight (lbs) |
|-------------|------------|-----|-----------------|------|------|--------------|
| | | | S | D | L | |
| 18-429-050 | 1½" | 11 | 0.94 | 3.78 | 8.07 | 1.30 |
| 18-429-020 | 2" | 11 | 1.14 | 4.44 | 9.17 | 1.96 |

Check homeflexunderground.com for up-to-date product listings.


Elbow Fitting Dimensional Information



| Part Number | Size (IPS) | SDR | Dimensions (in) | | | Weight (lbs) |
|---------------|------------|-----|-----------------|------|------|--------------|
| | | | S | D | L | |
| 18-406-005 | ½" | 9.3 | 0.47 | 1.81 | 2.72 | 0.20 |
| 18-406-007 | ¾" | 11 | 0.51 | 2.13 | 3.23 | 0.33 |
| 18-406-010 | 1" | 11 | 0.63 | 2.68 | 3.78 | 0.57 |
| 18-429-012-10 | 1¼" | 10 | 0.79 | 3.23 | 4.41 | 0.99 |
| 18-406-012 | 1¼" | 11 | 0.79 | 3.23 | 4.41 | 0.99 |
| 18-406-050 | 1½" | 11 | 0.83 | 3.78 | 4.84 | 1.48 |
| 18-406-020 | 2" | 11 | 0.94 | 4.45 | 5.59 | 2.29 |

Check homeflexunderground.com for up-to-date product listings.

Tee Fitting Dimensional Information




| Part Number | Size (IPS) | SDR | Dimensions (in) | | | | | Weight (lbs) |
|---------------|------------|-----|-----------------|------|------|------|------|--------------|
| | | | S | D | H | G | L | |
| 18-406-005 | ½" | 9.3 | 0.47 | 1.81 | 2.76 | 1.10 | 5.51 | 0.29 |
| 18-406-007 | ¾" | 11 | 0.51 | 2.13 | 3.19 | 1.54 | 6.34 | 0.49 |
| 18-406-010 | 1" | 11 | 0.63 | 2.68 | 3.78 | 1.69 | 7.44 | 0.86 |
| 18-406-012-10 | 1¼" | 10 | 0.79 | 3.23 | 4.41 | 1.89 | 8.78 | 1.46 |
| 18-406-012 | 1¼" | 11 | 0.79 | 3.23 | 4.41 | 1.89 | 8.78 | 1.46 |
| 18-406-015 | 1½" | 11 | 0.83 | 3.78 | 4.88 | 2.17 | 9.65 | 2.16 |
| 18-406-020 | 2" | 11 | 0.94 | 4.45 | 5.59 | 2.72 | 11.1 | 3.33 |


Check homeflexunderground.com for up-to-date product listings.

2.3 Conversion Fittings

- Converts between Steel and MDPE Gas Pipe
- Complies with ASTM F1973 for use with ASTM D2513 Gas Pipe
- Suitable for Natural Gas or LP Gas
- Maximum Operating Pressure: 125 PSIG
- Operating Temperature Range: -20°F - 180°F

| | Part No. | Description | SDR |
|---|------------|------------------|-----|
|  <p>HOME-FLEX® Fitting Male Pipe Threads</p> | 18-436-005 | ½" IPS to ½" MIP | 9.3 |
| | 18-436-007 | ¾" IPS to ¾" MIP | 11 |
| | 18-436-010 | 1" IPS to 1" MIP | 11 |

Conversion Fitting Dimensional Information




| Part Number | Size (IPS) | SDR | Dimensions (in) | | | | Weight (lbs) |
|-------------|------------|-----|-----------------|------|------|------|--------------|
| | | | S | D | L | L1 | |
| 18-436-005 | ½" | 9.3 | 0.67 | 1.81 | 3.94 | 3.33 | 0.23 |
| 18-436-007 | ¾" | 11 | 0.81 | 2.13 | 4.41 | 3.74 | 0.34 |
| 18-436-010 | 1" | 11 | 0.87 | 2.66 | 5.43 | 4.13 | 0.56 |

2.4 Transition Fittings

- Transitions between Steel and MDPE Gas Pipe
- Requires the use of a Coupling Fitting
- Complies with ASTM F1973 for use with ASTM D2513 Gas Pipe
- Suitable for Natural Gas or LP Gas
- Maximum Operating Pressure: 80 PSIG
- Operating Temperature Range: 0°F - 140°F

Note: The steel portion of this fitting has an epoxy coating to protect it from underground rust and corrosion. Inspect this coating carefully after installation. If any part of this coating has been nicked, chipped, or scratched, apply a rust proof coating or wrap with anti-corrosion tape. Be sure that no bare metal is exposed before burying.


| | Part No. | Description | SDR |
|---|------------|--------------------|-----|
|  | 18-445-005 | ½" IPS to ½" MIP | 9.3 |
| | 18-445-007 | ¾" IPS to ¾" MIP | 11 |
| | 18-445-010 | 1" IPS to 1" MIP | 11 |
| | 18-445-012 | 1¼" IPS to 1¼" MIP | 11 |
| | 18-445-015 | 1½" IPS to 1½" MIP | 11 |
| | 18-445-020 | 2" IPS to 2" MIP | 11 |

Check homeflexunderground.com for up-to-date product listings.

2.5 Anodeless Service Riser

- Required when bringing MDPE Gas Pipe above ground
- 30-inch rise from bottom of trench to top of pipe threads
- Requires the use of a Coupling Fitting
- Complies with ASTM F1973
- Complies with ASTM D2513 - Category 1 Specifications
- Suitable for Natural Gas or LP Gas
- Maximum Operating Pressure: 80 PSIG
- Operating Temperature Range: 0°F - 140°F

Note: The steel portion of this fitting has an epoxy coating to protect it from underground rust and corrosion. Inspect this coating carefully after installation. If any part of this coating has been nicked, chipped, or scratched, apply a rust proof coating or wrap with anti-corrosion tape. Be sure that no bare metal is exposed before burying.

| | Part No. | Description | SDR |
|---|------------|-------------------------|-----|
|  | 18-440-705 | ½" IPS poly to ¾" MIP | 9.3 |
| | 18-440-007 | ¾" IPS poly to ¾" MIP | 11 |
| | 18-440-010 | 1" IPS poly to 1" MIP | 11 |
| | 18-440-012 | 1¼" IPS poly to 1¼" MIP | 11 |
| | 18-440-015 | 1½" IPS poly to 1½" MIP | 11 |
| | 18-440-020 | 2" IPS poly to 2" MIP | 11 |

Check homeflexunderground.com for up-to-date product listings.

Chapter 3: System Configuration and Sizing

3.1 Configuration

Prior to piping installation, refer to building plans or prepare a sketch (this may be required by the local authority having jurisdiction for permitting purposes) showing the location of the appliances, the various appliance load demands, point of delivery (gas meter or 2nd stage LP regulator) and planned piping routes. Appliance load demand data can be obtained from the manufacturer's name-plate located on each appliance, or provided to the system designer by the builder/contractor.

Determine local piping restrictions prior to installing the underground piping system. Confirm that the AHJ (local authority having jurisdiction) has accepted the use of medium density polyethylene (MDPE listed to ASTM D2513) gas piping and fittings listed to ASTM F1924. MDPE has been accepted by most major code bodies, but state and/or local adoptions of these codes often lag behind.

Determine metered supply pressure:

- Natural Gas: Check with local gas utility to determine pressure supplied by the meter.
- Liquefied Petroleum Gas (LP Gas, also called Propane): Check with LP supplier to determine pressure supplied by the first and second stage regulators.

Informational Notes:

- Natural gas pressures: Typical natural gas appliances require 5 inches of water column (inches of water column is a measurement of pressure that uses a different scale to more accurately measure low pressure gas – i.e. $\frac{1}{4}$ PSI = 6.921 inches of water column). In the past, standard low pressure was typically provided at 6-7 inches of water column by the meter (and still is in many places) thus allowing for a 1" WC pressure drop. With the popularity of on-demand water heaters, commercial type cook stoves, and gas appliances in general, many utilities now provide 2 PSI of pressure from the outlet of the meter. Because there is no national standard for meter outlet pressures, it is critical to contact the utility to determine the pressure. Please note that when the outlet pressure of the meter is 2 PSI a line pressure regulator must be placed in the piping system upstream from the connection of a manifold or appliance.
- LP gas: Check with both the AHJ and LP supplier for their acceptance of MDPE piping.

Determine the total capacity needed for all appliances. The capacity tables within this guide should be used to determine pipe sizes necessary to meet BTUH input load requirements.

With respect to gas pipe sizing, the intent of all model codes is to ensure there is sufficient gas volume and gas pressure supplied to the appliance for proper operation. Language from the International Fuel Gas Code clearly illustrates this point:

***Allowable Pressure Drop:** The design pressure loss on any piping system under maximum probable flow conditions, from the point of delivery to the inlet connection of the equipment, shall be such that supply pressure at the equipment is greater than the minimum required for proper equipment operation.*

Important Considerations:

- All existing pipe sizes within a gas piping system should be evaluated and confirmed to be adequate to handle the additional load when adding additional appliances.
- Allowable pressure drop along any particular run may be dictated by local code restrictions.
- Call 811 at least 3 days prior to digging.

3.2 Reference Data for Proper Sizing

| |
|---|
| ¼ PSI = 6.921 in. w.c. (approx. 7 in. w.c.) |
| ½ PSI = 13.842 in. w.c. (approx. 14 in. w.c.) |
| 1 PSI = 27.684 in. w.c. (approx. 28 in. w.c.) |
| 2 PSI = 55.368 in. w.c. (approx. 56 in. w.c.) |
| 5 PSI = 138.42 in. w.c. (approx. 40 in. w.c.) |

| Gas Type | BTU per Cubic Foot | Specific Gravity |
|-------------|--------------------|------------------|
| Natural Gas | 1000 | 0.6 |
| LP Gas | 2516 | 1.52 |

Note: To determine the CFH of Natural Gas, divide BTU load by 1000. To determine CFH of LP, divide the BTU load by 2516.

3.3 Sizing Methods and Examples

Low Pressure (Less than or equal to 2.0 PSI Natural Gas)

In this scenario, an underground polyethylene gas line is being ran from the low pressure outlet of the meter to a detached garage, outbuilding, or appliance that requires a natural gas outlet.




Figure 3.1 2 PSI Natural Gas Supply from House to Garage

Step 1 Call 811 at least 3 days prior to digging to have any underground utilities marked prior to digging.

Step 2 Determine length of gas piping from connection point at meter outlet to riser outlet at the out building or appliance. Include the distance required to connect the riser to the gas piping system near the meter. This connection must be made using rigid pipe or CSST that is at least the same size as the PE pipe size.

Step 3 Determine the number and type of HOME-FLEX Underground® fittings that are required in the system. Add the equivalent number of feet from Table 5.1 “Length to Add to Each Run for Each Fitting” on page 20 of this guide to the number of feet calculated above.

Step 4 Determine the appropriate sizing table in Chapter 5 based on meter outlet pressure and allowable pressure drop. For example, Table 5.2 on page 21 can be used for low pressure with a pressure drop of 0.3” w.c. Find the nearest length that is equal to or greater than the length calculated in step 3 above. Follow the row across until the number of BTU’s provided is equal to or greater than the required BTU’s required for this run- check the column header for required pipe diameter.

Low Pressure (Less than or equal to 2.0 PSI) LP Gas

In this scenario, an underground polyethylene gas line is being run from the outlet of the second-stage regulator to a detached garage, outbuilding, or appliance that requires an LP gas outlet.

System Configuration and Sizing




Figure 3.2 2 PSI LP Gas Second-Stage Regulator To Garage, Outbuilding Or Appliance.

Step 1 Call 811 at least 3 days prior to digging to have any underground utilities marked prior to digging.

Step 2 Determine length of gas piping from connection point at second stage regulator outlet to riser outlet at the outbuilding or appliance. Include the distance required to connect the riser to the gas piping system near the meter. This connection must be made using rigid pipe or CSST that is at least the same size as the PE pipe size.

Step 3 Determine the number and type of HOME-FLEX Underground® fittings that are required in the system. Add the equivalent number of feet from Table 5.1 "Length to Add to Each Run for Each Fitting" on page 20 of this guide to the number of feet calculated above.

Step 4 Determine the appropriate LP Gas sizing table based on the Second-Stage Regulator pressure and allowable pressure drop using the appropriate sizing table in Chapter 5. For example, Table 5.5 on page 24 can be used for low pressure LP gas with a pressure drop of 0.5" w.c. Find the nearest length that is equal to or greater than the length calculated in step above. Follow the row across until the number of BTU's provided is equal to or greater than the required BTU's required for this run- check the column header for required pipe diameter.

Elevated Pressure (10 PSI) LP Gas

In this scenario, an underground polyethylene gas line is being run from the outlet of the LP Gas tank's First-Stage Regulator to the Second-Stage Regulator.




Figure 3.3 10 PSI LP Gas First-Stage Regulator (Tank) to Second-Stage Regulator (House)

Step 1 Call 811 at least 3 days prior to digging to have any underground utilities marked prior to digging.

Step 2 Determine length of gas piping from connection point of riser near first-stage regulator outlet to riser outlet at the second stage-regulator. LP provider will make connection from first stage regulator to riser.

Step 3 Determine the number and type of HOME-FLEX Underground® fittings that are required in the system. Add the equivalent number of feet from Table 5.1 "Length to Add to Each Run for Each Fitting" on page 20 of this guide to the number of feet calculated above.

Step 4 Use Table 5.7 on page 26 for 10 PSI elevated pressure LP Gas. Find the nearest length that is equal to or greater than the length calculated in step 3 above. Follow the row across until the number of BTU's provided is equal to or greater than the required BTU's required for this run - check the column header for required pipe diameter.

Chapter 4: Installation Practices

4.1 Installation Practices and Guidelines

1. HOME-FLEX Underground pipe and fittings must be installed in accordance with the Installation Practices & Guidelines outlined in this document as well as all local plumbing, mechanical, electrical and/or building codes and laws applicable at the locale where HOME-FLEX Underground is to be installed. If you do not understand all aspects of the installation requirements and local codes, locate a qualified installer in your area who does.
2. Only the components provided or specified by Valencia Pipe Company as part of the piping system are to be used in the installation.
3. Never use HOME-FLEX Underground products in above-ground applications.
4. Never use HOME-FLEX Underground products inside buildings.
5. Never install HOME-FLEX Underground pipe or fittings under a building.
6. Never encase HOME-FLEX Underground products in concrete.
7. Do not use HOME-FLEX Underground pipe fittings to connect poly gas pipes other than the specified size as marked on the fitting.
8. The minimum required depth for buried pipe will be specified by local code. If the local code does not include trench specifications, then trench and backfill in accordance with ASTM D2774 “Standard Practice for Underground Installation of Thermoplastic Pressure Piping” available at: astm.org/Standard/standards-and-publications.html. Consult Section 4.2 (p. 15) for more trenching guidelines.
9. Underground gas piping must be installed with sufficient clearance from any other underground structure to avoid contact, to allow maintenance, and to protect against damage from proximity to other structures. In addition, underground plastic piping shall be installed with sufficient clearance, or shall be insulated from any source of heat so as to prevent heat from impairing the serviceability and reliability of the pipe.
10. Ensure that correct stiffener is used with the correct sized pipe (size is marked on stiffener).
11. Ensure the sizing on the fitting nut matches the sizing on the pipe being connected.
12. The fitting is supplied assembled and ready to use. If the fitting is disassembled, ensure all nut components are present and in the correct orientation as pictured in Figure 4.1 (p. 15).
13. When installing PE pipe care must be taken to avoid inducing excessive stresses to the pipe and fittings.
14. Excessive bending of plastic piping systems, particularly at joints, can exceed stress limits and result in failure. Pipe, when joined with fittings, shall be laid as true to line as possible, while taking into consideration that common PE gas pipe may expand or contract 1 inch for every 10° F of temperature change per each 100 foot section of pipe. Grading and backfilling must be carried out carefully to prevent uneven settlement and therefore excessive bending. Please refer to ASTM D2774 for additional information on backfilling.
15. The use of damaged pipe where the joint is being made must be avoided. If there is a cut or groove in the pipe that section should be cut out. Sealing performance can be affected by scored or damaged pipe, so caution should be taken if present on the pipe.
16. The HOME-FLEX Underground® gas piping system must be pressure tested for leaks in accordance with all local codes. In the absence of a specific local code that specifies the pressure test, refer to the latest edition of the National Fuel Gas Code NFPA 54 which

can be obtained from: catalog.nfpa.org/NFPA-54-C3324.aspx. Consult Section 4.4 (p. 18) for more information on pressure / leak tests and troubleshooting leaks.



Figure 4.1 Fitting Re-assembly Diagrams

4.2 Trenching

The minimum required depth for buried pipe will be specified by local code, and may range from as shallow as 12 inches to as deep as 24 inches. The width of the trench should be sufficient for the width of the widest fitting. A 12 inch wide trench will allow for sufficient clearance of the pipe and fittings. The bottom of the trench should be smooth and flat. The plumbing code requirements at the installation location must be followed.

Keep in mind that trench depth requirements are measured from ground level to the top of the piping system, including the fittings. For example, if the minimum required depth, or amount of cover, per code is 18 inches and 1-inch pipe is being installed, the trench depth will be a minimum of 20.68 inches (18 inches plus the fitting depth of 2.68 inches). Fitting depth information can be found in Section 2.2 (p. 5). Be sure that trenches comply with your local code requirements.

Underground Piping Detectability Requirements

In the trench next to the gas pipe, install a 14 gauge or thicker insulated copper tracer wire. This wire will make the underground routing of the poly gas pipe detectable from above ground. The ends of the tracer wire should follow the riser above ground and be visible for future use. Some locations may also require the installation of plastic caution tape to be buried in the trench several inches above the gas pipe. Consult the local code at the installation location to ensure compliance with piping detectability requirements.

Backfilling Trenches


If the local code does not include trench specifications, then prepare trenches and backfill in accordance with ASTM D2774 "Standard Practice for Underground Installation of Thermoplastic Pressure Piping," which can be downloaded from: astm.org/Standard/standards-and-publications.html. Ensure that the fill dirt is free of debris or rocks that could damage the pipe when the earth is compressed around it. Do not backfill

Installation Practices

the trench until after the pressure / leak test has been completed (see Section “4.4 Pressure and Leak Testing” on page 18) and the system has passed inspection by the local authority having jurisdiction (AHJ).

4.3 Fitting Assembly Overview

HOME-FLEX Underground® IPS fittings are for use with IPS sized yellow poly gas pipe that has been approved for use with natural gas and propane.



Step 1 Check contents

Each product package includes a fitting and a number of stiffeners to be used on each end of pipe being connected (i.e. 2 stiffeners for a Coupler or Elbow, 3 for a Tee).



Step 2 Cut the pipe square

There is no need to chamfer the pipe end. Ensure any burrs on the pipe are removed and the pipe is clean.

Step 3 Insert stiffeners

Insert the supplied stiffeners into each end of the pipe being connected.





Step 4 Push stiffener into pipe

Push the stiffener all the way into the pipe until the ridge is flush with the pipe end. This can be done by hand, or gently tapped in with a mallet if required.

Step 5 Ensure 3 threads are showing on the fitting body

The fitting is supplied in a ready-to-use position. You do not need to disassemble the fitting prior to use. Always ensure three threads are exposed on the central body of the fitting prior to use.



Step 6 Insert the pipe into the fitting

Gently slide the pipe with stiffener into the fitting until it stops. No force is required to do this. Do not try to force the pipe further into the fitting.



Step 7 Tighten the fitting

While holding the end of the pipe into the fitting with gentle force, tighten the nut until the nut touches the flange on the central body of the fitting. Do not tighten further once the nut touches the flange as over tightening can damage the fitting. It is recommended that pliers are used to ensure that the nut is tight against the body of the fitting.

Step 8 Fitting is installed

The fitting is now fully installed and ready for use. Note nut position relative to the flange on the central body. **Check for system leaks prior to backfilling.**



WARNING! Improper installation or operation of the system may result in fire, explosion, or asphyxiation. Only the components provided or specified by Valencia Pipe Company for use with HOME-FLEX Underground® or as part of the fuel gas system are to be used in the installation.

4.4 Pressure and Leak Testing

The HOME-FLEX Underground® gas piping system must be pressure tested for leaks in accordance with all local codes. The system must pass the pressure / leak test and have passed inspection by the authority having jurisdiction (AHJ) before backfilling the trench. In the absence of a specific local code that specifies the pressure test, refer to the latest edition of the National Fuel Gas Code NFPA 54. A copy of this code can be purchased and downloaded from: catalog.nfpa.org/NFPA-54-C3324.aspx.

Be sure that the new installation is isolated from any existing piping and the meter or regulator supply prior to conducting a pressure / leak test. A typical pressure / leak test for a single family residence might consist of pressurizing the newly installed pipe and fitting system with air to 15 PSI:

- Watch the needle on the pressure gauge for 15 - 30 minutes.
- If there is no detectable loss of pressure, this indicates that the system holds pressure.

NFPA 54 specifies that the system should be tested at 1.5 times the intended system operating pressure, but never less than 3 PSI. Long duration pressure / leak tests are not ideal, because the change of air temperature in the piping system will affect the reading on the pressure gauge. For each 10°F reduction in air temp, anticipate a 1.9% reduction in air pressure due to the cooling and contraction of the air in the pipe.

Troubleshooting Fitting Assembly and Correcting Leaks

If a leak is detected, check the following:

Step 1 Ensure that all yellow nuts on the fitting are tight up against the black body of the fitting. If they are and leak persists, go to step 2.

Step 2 Loosen the yellow nut and remove the pipe from the fitting.

- Examine the inside of the fittings to make sure it is free of dirt or any debris that will interfere with the outside of the pipe making a seal against the inside of the fitting.
- Make sure that the outside of the pipe is clean and smooth.
- Reassemble the pipe into the fitting follow the assembly instructions and check for leaks.

Note: It is not necessary to remove the yellow nut completely off of the fitting. If this occurs refer to Figure 4.1 (p. 15).

Chapter 5: Sizing/Capacity Tables

Fitting Adjustment Values for Determining Run Length

| | |
|---|----|
| Table 5.1 Length to Add to Each Run for Each Fitting..... | 20 |
|---|----|

Natural Gas Sizing Tables

| | |
|--|----|
| Table 5.2 Low Pressure Natural Gas (Less than 2 PSI with 0.3 in. w.c. drop)..... | 21 |
| Table 5.3 Low Pressure Natural Gas (Less than 2 PSI with 0.5 in. w.c. drop)..... | 22 |
| Table 5.4 Elevated Pressure Natural Gas (2 PSI with 1 PSI drop)..... | 23 |

Liquid Petroleum (LP) Sizing Tables

| | |
|---|----|
| Table 5.5 Low Pressure LP (Less than 11 in. w.c. with 0.5 in. w.c. drop)..... | 24 |
| Table 5.6 Elevated Pressure LP (2 PSI with 1 PSI drop)..... | 25 |
| Table 5.7 Elevated Pressure Liquid Propane (LP) (10 PSI with 1 PSI drop)..... | 26 |

5.1 Fitting Adjustment Values for Determining Run Length

Table 5.1 Length to Add to Each Run for Each Fitting

| Fitting | Pipe Size | Add |
|---------------------------|-----------|-------|
| Coupler | ½" | 1.6' |
| | ¾" | 2.2' |
| | 1" | 2.9' |
| | 1¼" | 3.5' |
| | 1½" | 4.2' |
| | 2" | 3.4' |
| Elbow | ½" | 3.2' |
| | ¾" | 4.4' |
| | 1" | 5.7' |
| | 1¼" | 6.9' |
| | 1½" | 8.2' |
| | 2" | 8.3' |
| Tee (In Line Flow) | ½" | 2.1' |
| | ¾" | 2.9' |
| | 1" | 3.7' |
| | 1¼" | 4.5' |
| | 1½" | 5.3' |
| | 2" | 4.8' |
| Tee (line to branch flow) | ½" | 3.8' |
| | ¾" | 5.3' |
| | 1" | 6.8' |
| | 1¼" | 8.4' |
| | 1½" | 9.9' |
| | 2" | 10.4' |

5.2 Natural Gas Sizing Tables

Table 5.2 Low Pressure Natural Gas (Less than 2 PSI with 0.3 in. w.c. drop)

Maximum Capacity of HOME-FLEX Underground® Poly Pipe in BTU/h (British Thermal Units per Hour) of Natural Gas by Length of Piping Run

(Approximate 1,000 BTU/h Natural Gas per 1 CFH; based on a 0.6 specific gravity of gas)

Inlet Pressure: **Less than 2 PSI**

Pressure Drop: **0.3 in w.c.**

| Run (ft.) | IPS Pipe Size (SDR) | | | | | |
|-----------|---------------------|-------------|-------------|--------------|--------------|-------------|
| | ½" (SDR 9.3) | ¾" (SDR 11) | 1" (SDR 11) | 1¼" (SDR 10) | 1½" (SDR 11) | 2" (SDR 11) |
| 10 | 153k | 305k | 551k | 955k | 1,440k | 2,590k |
| 20 | 105k | 210k | 379k | 656k | 991k | 1,780k |
| 30 | 84k | 169k | 304k | 527k | 796k | 1,430k |
| 40 | 72k | 144k | 260k | 451k | 681k | 1,220k |
| 50 | 64k | 128k | 231k | 400k | 604k | 1,080k |
| 60 | 58k | 116k | 209k | 362k | 547k | 983k |
| 70 | 53k | 107k | 192k | 333k | 503k | 904k |
| 80 | 50k | 99k | 179k | 310k | 468k | 841k |
| 90 | 46k | 93k | 168k | 291k | 439k | 789k |
| 100 | 44k | 88k | 159k | 275k | 415k | 745k |
| 125 | 39k | 78k | 141k | 243k | 368k | 661k |
| 150 | 35k | 71k | 127k | 221k | 333k | 598k |
| 175 | 32k | 65k | 117k | 203k | 306k | 551k |
| 200 | 30k | 60k | 109k | 189k | 285k | 512k |
| 250 | 27k | 54k | 97k | 167k | 253k | 454k |
| 300 | 24k | 48k | 88k | 152k | 229k | 411k |
| 350 | 22k | 45k | 81k | 139k | 211k | 378k |
| 400 | 21k | 42k | 75k | 130k | 196k | 352k |
| 450 | 19k | 39k | 70k | 122k | 184k | 330k |
| 500 | 18k | 37k | 66k | 115k | 174k | 312k |

k = 1,000 BTU/h

EXAMPLE: 10k = 10,000 BTU/h = 10 CFH (Cubic Feet per Hour) of Natural Gas

Sizing/Capacity Tables

Table 5.3 Low Pressure Natural Gas (Less than 2 PSI with 0.5 in. w.c. drop)

Maximum Capacity of HOME-FLEX Underground® Poly Pipe in BTU/h (British Thermal Units per Hour) of Natural Gas by Length of Piping Run

(Approximate 1,000 BTU/h Natural Gas per 1 CFH; based on a 0.6 specific gravity of gas)

Inlet Pressure: **Less than 2 PSI**

Pressure Drop: **0.5 in w.c.**

| Run (ft.) | IPS Pipe Size (SDR) | | | | | |
|-----------|---------------------|-------------|-------------|--------------|--------------|-------------|
| | ½" (SDR 9.3) | ¾" (SDR 11) | 1" (SDR 11) | 1¼" (SDR 10) | 1½" (SDR 11) | 2" (SDR 11) |
| 10 | 201k | 403k | 726k | 1,260k | 1,900k | 3,410k |
| 20 | 138k | 277k | 499k | 865k | 1,310k | 2,350k |
| 30 | 111k | 222k | 401k | 695k | 1,050k | 1,880k |
| 40 | 95k | 190k | 343k | 594k | 898k | 1,610k |
| 50 | 84k | 169k | 304k | 527k | 796k | 1,430k |
| 60 | 76k | 153k | 276k | 477k | 721k | 1,300k |
| 70 | 70k | 140k | 254k | 439k | 663k | 1,190k |
| 80 | 65k | 131k | 236k | 409k | 617k | 1,110k |
| 90 | 61k | 123k | 221k | 383k | 579k | 1,040k |
| 100 | 58k | 116k | 209k | 362k | 547k | 983k |
| 125 | 51k | 103k | 185k | 321k | 485k | 871k |
| 150 | 46k | 93k | 168k | 291k | 439k | 789k |
| 175 | 43k | 86k | 154k | 268k | 404k | 726k |
| 200 | 40k | 80k | 144k | 249k | 376k | 675k |
| 250 | 35k | 71k | 127k | 221k | 333k | 598k |
| 300 | 32k | 64k | 115k | 200k | 302k | 542k |
| 350 | 29k | 59k | 106k | 184k | 278k | 499k |
| 400 | 27k | 55k | 99k | 171k | 258k | 464k |
| 450 | 26k | 51k | 93k | 160k | 242k | 435k |
| 500 | 24k | 48k | 88k | 152k | 229k | 411k |

k = 1,000 BTU/h

EXAMPLE: 10k = 10,000 BTU/h = 10 CFH (Cubic Feet per Hour) of Natural Gas

Table 5.4 Elevated Pressure Natural Gas (2 PSI with 1 PSI drop)

Maximum Capacity of HOME-FLEX Underground® Poly Pipe in BTU/h (British Thermal Units per Hour) of Natural Gas by Length of Piping Run

(Approximate 1,000 BTU/h Natural Gas per 1 CFH; based on a 0.6 specific gravity of gas)

Inlet Pressure: **2 PSI**

Pressure Drop: **1 PSI**

| Run (ft.) | IPS Pipe Size (SDR) | | | | | |
|-----------|---------------------|-------------|-------------|--------------|--------------|-------------|
| | ½" (SDR 9.3) | ¾" (SDR 11) | 1" (SDR 11) | 1¼" (SDR 10) | 1½" (SDR 11) | 2" (SDR 11) |
| 10 | 1,860k | 3,720k | 6,710k | 11,600k | 17,600k | 31,600k |
| 20 | 1,280k | 2,560k | 4,610k | 7,990k | 12,100k | 21,700k |
| 30 | 1,030k | 2,050k | 3,710k | 6,420k | 8,690k | 17,400k |
| 40 | 878k | 1,760k | 3,170k | 5,490k | 8,300k | 14,900k |
| 50 | 778k | 1,560k | 2,810k | 4,870k | 7,350k | 13,200k |
| 60 | 705k | 1,410k | 2,550k | 4,410k | 6,660k | 12,000k |
| 70 | 649k | 1,300k | 2,340k | 4,060k | 6,130k | 11,000k |
| 80 | 603k | 1,210k | 2,180k | 3,780k | 5,700k | 10,200k |
| 90 | 566k | 1,130k | 2,050k | 3,540k | 5,250k | 9,610k |
| 100 | 535k | 1,070k | 1,930k | 3,350k | 5,050k | 9,080k |
| 125 | 474k | 949k | 1,710k | 2,970k | 4,480k | 8,050k |
| 150 | 429k | 860k | 1,550k | 2,690k | 4,060k | 7,290k |
| 175 | 395k | 791k | 1,430k | 2,470k | 3,730k | 6,710k |
| 200 | 368k | 736k | 1,330k | 2,300k | 3,470k | 6,240k |
| 250 | 326k | 652k | 1,180k | 2,040k | 3,080k | 5,530k |
| 300 | 295k | 591k | 1,070k | 1,850k | 2,790k | 5,010k |
| 350 | 272k | 544k | 981k | 1,700k | 2,570k | 4,610k |
| 400 | 253k | 506k | 913k | 1,580k | 2,390k | 4,290k |
| 450 | 237k | 475k | 856k | 1,480k | 2,240k | 4,020k |
| 500 | 224k | 448k | 809k | 1,400k | 2,120k | 3,800k |
| 550 | 213k | 426k | 768k | 1,330k | 2,010k | 3,610k |
| 600 | 203k | 406k | 733k | 1,270k | 1,920k | 3,440k |
| 650 | 194k | 389k | 702k | 1,220k | 1,840k | 3,300k |
| 700 | 187k | 374k | 674k | 1,170k | 1,760k | 3,170k |
| 750 | 180k | 360k | 649k | 1,130k | 1,700k | 3,050k |
| 800 | 174k | 348k | 627k | 1,090k | 1,640k | 2,950k |
| 850 | 168k | 336k | 607k | 1,050k | 1,590k | 2,850k |
| 900 | 163k | 326k | 588k | 1,020k | 1,540k | 2,770k |
| 950 | 158k | 317k | 572k | 990k | 1,500k | 2,690k |
| 1000 | 154k | 308k | 556k | 963k | 1,450k | 2,610k |
| 1100 | 146k | 293k | 528k | 915k | 1,380k | 2,480k |
| 1200 | 139k | 279k | 504k | 873k | 1,320k | 2,370k |
| 1300 | 134k | 267k | 482k | 836k | 1,260k | 2,270k |
| 1400 | 128k | 257k | 463k | 803k | 1,210k | 2,180k |
| 1500 | 124k | 247k | 446k | 773k | 1,170k | 2,100k |
| 1600 | 119k | 239k | 431k | 747k | 1,130k | 2,030k |
| 1700 | 115k | 231k | 417k | 723k | 1,090k | 1,960k |
| 1800 | 112k | 224k | 404k | 701k | 1,060k | 1,900k |
| 1900 | 109k | 218k | 393k | 680k | 1,030k | 1,850k |
| 2000 | 106k | 212k | 382k | 662k | 1,000k | 1,800k |

k = 1,000 BTU/h EXAMPLE: 10k = 10,000 BTU/h = 10 CFH (Cubic Feet per Hour) of Natural Gas

5.3 Liquid Petroleum (LP) Gas Sizing Tables

Table 5.5 Low Pressure LP (Less than 11 in. w.c. with 0.5 in. w.c. drop)

Maximum Capacity of HOME-FLEX Underground® Poly Pipe in BTU/h (British Thermal Units per Hour) of Liquid Propane (LP) Gas by Length of Piping Run

(Approximate 2,520 BTU/h LP Gas per 1 CFH; based on a 1.52 specific gravity of gas)

Inlet Pressure: **11 in. w.c.**

Pressure Drop: **0.5 in. w.c.**

Intended Use: PE Pipe Sizing Between Integral Second-Stage Regulator at Tank or Second-Stage (Low-Pressure) Regulator and Building

| Run (ft.) | IPS Pipe Size (SDR) | | | | | |
|-----------|---------------------|-------------|-------------|--------------|--------------|-------------|
| | ½" (SDR 9.3) | ¾" (SDR 11) | 1" (SDR 11) | 1¼" (SDR 10) | 1½" (SDR 11) | 2" (SDR 11) |
| 10 | 340k | 680k | 1,230k | 2,130k | 3,210k | 5,770k |
| 20 | 233k | 468k | 844k | 1,460k | 2,210k | 3,970k |
| 30 | 187k | 375k | 677k | 1,170k | 1,770k | 3,180k |
| 40 | 160k | 321k | 580k | 1,000k | 1,520k | 2,730k |
| 50 | 142k | 285k | 514k | 890k | 1,340k | 2,420k |
| 60 | 129k | 258k | 466k | 807k | 1,220k | 2,190k |
| 70 | 119k | 237k | 428k | 742k | 1,120k | 2,010k |
| 80 | 110k | 221k | 398k | 690k | 1,040k | 1,870k |
| 90 | 103k | 207k | 374k | 648k | 978k | 1,760k |
| 100 | 98k | 196k | 353k | 612k | 924k | 1,660k |
| 125 | 87k | 173k | 313k | 542k | 819k | 1,470k |
| 150 | 78k | 157k | 284k | 491k | 742k | 1,330k |
| 175 | 72k | 145k | 261k | 452k | 683k | 1,230k |
| 200 | 67k | 135k | 243k | 420k | 635k | 1,140k |
| 250 | 60k | 119k | 215k | 373k | 563k | 1,010k |
| 300 | 54k | 108k | 195k | 338k | 510k | 916k |
| 350 | 50k | 99k | 179k | 311k | 469k | 843k |
| 400 | 46k | 92k | 167k | 289k | 436k | 784k |
| 450 | 43k | 87k | 157k | 271k | 409k | 736k |
| 500 | 41k | 82k | 148k | 256k | 387k | 695k |

k = 1,000 BTU/h

EXAMPLE: 252k = 252,000 BTU/h = 100 CFH (Cubic Feet per Hour) of LP Gas

Table 5.6 Elevated Pressure LP (2 PSI with 1 PSI drop)**Maximum Capacity of HOME-FLEX Underground® Poly Pipe in BTU/h (British Thermal Units per Hour) of Liquid Propane (LP) Gas by Length of Piping Run**

(Approximate 2,520 BTU/h LP Gas per 1 CFH; based on a 1.52 specific gravity of gas)

Inlet Pressure: **2 PSI**Pressure Drop: **1 PSI**

Intended Use: PE Pipe Sizing Between 2 PSI Service Regulator and Line Pressure Regulator

| Run (ft.) | IPS Pipe Size (SDR) | | | | | |
|-----------|---------------------|-------------|-------------|--------------|--------------|-------------|
| | ½" (SDR 9.3) | ¾" (SDR 11) | 1" (SDR 11) | 1¼" (SDR 10) | 1½" (SDR 11) | 2" (SDR 11) |
| 10 | 3,130k | 6,260k | 11,300k | 19,600k | 29,500k | 53,100k |
| 20 | 2,150k | 4,300k | 7,760k | 13,400k | 20,300k | 36,500k |
| 30 | 1,730k | 3,450k | 6,230k | 10,800k | 16,300k | 29,300k |
| 40 | 1,480k | 2,690k | 5,330k | 9,240k | 14,000k | 25,100k |
| 50 | 1,310k | 2,620k | 4,730k | 8,190k | 12,400k | 22,200k |
| 60 | 1,190k | 2,370k | 4,280k | 7,420k | 11,200k | 20,100k |
| 70 | 1,090k | 2,180k | 3,940k | 6,830k | 10,300k | 18,500k |
| 80 | 1,010k | 2,030k | 3,670k | 6,350k | 9,590k | 17,200k |
| 90 | 952k | 1,910k | 3,440k | 5,960k | 9,000k | 16,200k |
| 100 | 899k | 1,800k | 3,250k | 5,630k | 8,500k | 15,300k |
| 125 | 797k | 1,600k | 2,880k | 4,990k | 7,530k | 13,500k |
| 150 | 722k | 1,450k | 2,610k | 4,520k | 6,830k | 12,300k |
| 175 | 664k | 1,330k | 2,400k | 4,160k | 6,280k | 11,300k |
| 200 | 618k | 1,240k | 2,330k | 3,870k | 5,840k | 10,500k |
| 250 | 548k | 1,100k | 1,980k | 3,430k | 5,180k | 9,300k |
| 300 | 496k | 994k | 1,790k | 3,110k | 4,690k | 8,430k |
| 350 | 457k | 914k | 1,650k | 2,860k | 4,320k | 7,760k |
| 400 | 425k | 851k | 1,530k | 2,660k | 4,020k | 7,220k |
| 450 | 399k | 798k | 1,440k | 2,500k | 3,770k | 6,770k |
| 500 | 377k | 754k | 1,360k | 2,360k | 3,560k | 6,390k |
| 550 | 358k | 716k | 1,290k | 2,240k | 3,380k | 6,070k |
| 600 | 341k | 683k | 1,230k | 2,140k | 3,220k | 5,790k |
| 650 | 327k | 654k | 1,180k | 2,040k | 3,090k | 5,550k |
| 700 | 314k | 628k | 1,130k | 1,960k | 2,970k | 5,330k |
| 750 | 302k | 605k | 1,090k | 1,770k | 2,670k | 4,800k |
| 800 | 292k | 585k | 1,050k | 1,830k | 2,760k | 4,960k |
| 850 | 283k | 566k | 1,020k | 1,770k | 2,670k | 4,800k |
| 900 | 274k | 549k | 990k | 1,710k | 2,670k | 4,800k |
| 950 | 266k | 533k | 961k | 1,670k | 2,520k | 4,520k |
| 1000 | 259k | 518k | 935k | 1,620k | 2,450k | 4,400k |
| 1100 | 246k | 492k | 888k | 1,540k | 2,320k | 4,170k |
| 1200 | 234k | 470k | 847k | 1,470k | 2,220k | 3,980k |
| 1300 | 225k | 450k | 811k | 1,410k | 2,120k | 3,810k |
| 1400 | 216k | 432k | 779k | 1,350k | 2,040k | 3,660k |
| 1500 | 208k | 416k | 751k | 1,300k | 1,960k | 3,530k |
| 1600 | 201k | 402k | 725k | 1,260k | 1,900k | 3,410k |
| 1700 | 194k | 389k | 702k | 1,220k | 1,840k | 3,300k |
| 1800 | 188k | 377k | 680k | 1,180k | 1,780k | 3,200k |
| 1900 | 183k | 366k | 661k | 1,140k | 1,730k | 3,110k |
| 2000 | 178k | 356k | 643k | 1,110k | 1,680k | 3,020k |

k = 1,000 BTU/h

EXAMPLE: 252k = 252,000 BTU/h = 100 CFH (Cubic Feet per Hour) of LP Gas

Sizing/Capacity Tables

Table 5.7 Elevated Pressure Liquid Propane (LP) (10 PSI with 1 PSI drop)

Maximum Capacity of HOME-FLEX Underground® Poly Pipe in BTU/h (British Thermal Units per Hour) of Liquid Propane (LP) Gas by Length of Piping Run

(Approximate 2,520 BTU/h LP Gas per 1 CFH; based on a 1.52 specific gravity of gas)

Inlet Pressure: **10 PSI**

Pressure Drop: **1 PSI**

Intended Use: PE Pipe Sizing Between First-Stage Pressure Regulator and Second-Stage (Low Pressure) Regulator

| Run (ft.) | IPS Pipe Size (SDR) | | | | | |
|-----------|---------------------|-------------|-------------|--------------|--------------|-------------|
| | ½" (SDR 9.3) | ¾" (SDR 11) | 1" (SDR 11) | 1¼" (SDR 11) | 1½" (SDR 11) | 2" (SDR 11) |
| 30 | 2,140k | 4,290k | 7,740k | 13,420k | 20,300k | 36,400k |
| 40 | 1,840k | 3,670k | 6,630k | 11,480k | 17,300k | 31,200k |
| 50 | 1,630k | 3,260k | 5,870k | 10,180k | 15,400k | 27,600k |
| 60 | 1,470k | 2,950k | 5,320k | 9,220k | 13,900k | 25,000k |
| 70 | 1,360k | 2,710k | 4,900k | 8,480k | 12,800k | 23,000k |
| 80 | 1,260k | 2,530k | 4,560k | 7,890k | 11,900k | 21,400k |
| 90 | 1,180k | 2,370k | 4,270k | 7,400k | 11,200k | 20,100k |
| 100 | 1,120k | 2,240k | 4,040k | 6,990k | 10,600k | 19,000k |
| 125 | 990k | 1,980k | 3,580k | 6,200k | 9,360k | 16,800k |
| 150 | 897k | 1,800k | 3,240k | 5,620k | 8,480k | 15,200k |
| 175 | 826k | 1,650k | 2,980k | 5,170k | 7,800k | 14,000k |
| 200 | 778k | 1,540k | 2,780k | 4,810k | 7,260k | 13,000k |
| 225 | 721k | 1,440k | 2,600k | 4,510k | 6,810k | 12,200k |
| 250 | 681k | 1,360k | 2,460k | 4,260k | 6,430k | 11,600k |
| 275 | 646k | 1,290k | 2,340k | 4,050k | 6,110k | 11,000k |
| 300 | 617k | 1,240k | 2,230k | 3,860k | 5,830k | 10,470k |
| 350 | 567k | 1,140k | 2,050k | 3,550k | 5,360k | 9,640k |
| 400 | 528k | 1,060k | 1,910k | 3,300k | 4,990k | 8,970k |
| 450 | 495k | 992k | 1,790k | 3,100k | 4,680k | 8,410k |
| 500 | 468k | 937k | 1,690k | 2,930k | 4,420k | 7,950k |
| 600 | 424k | 849k | 1,530k | 2,650k | 4,010k | 7,200k |
| 700 | 390k | 781k | 1,410k | 2,440k | 3,690k | 6,620k |
| 800 | 363k | 726k | 1,310k | 2,270k | 3,430k | 6,160k |
| 900 | 340k | 682k | 1,230k | 2,130k | 3,220k | 5,780k |
| 1000 | 322k | 644k | 1,160k | 2,010k | 3,040k | 5,460k |
| 1500 | 258k | 517k | 933k | 1,620k | 2,440k | 4,390k |
| 2000 | 221k | 443k | 798k | 1,380k | 2,090k | 3,750k |

k = 1,000 BTU/h EXAMPLE: 252k = 252,000 BTU/h = 100 CFH (Cubic Feet per Hour) of LP Gas