SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

## **Diversified Industries**

121 High Hill Rd, Swedesboro, NJ, United States

For the following product(s):

## **Underlayments:**

floorMuffler: UltraSeal, Encore, LVT, QuietCure; Natura Elite

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## FloorScore<sup>®</sup>

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-07521

Valid from: January 1, 2023 to December 31, 2023

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, http://www.scsglobalservices.com/certified-green-products-guide.







Transcy Mathor Kam

Stanley Mathuram, PE, Executive Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA