



Underwriters Laboratories Inc.®

Northbrook, Illinois • (847) 272-8800

Melville, New York • (516) 271-6200

Santa Clara, California • (408) 985-2400

Research Triangle Park,
North Carolina • (919) 549-1400

Camas, Washington • (360) 817-5500

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 210497-E84967C
ISSUE DATE: April 21, 1997

Issued to: Square D Company
3700 6th Street S. W.
Cedar Rapids, IA 52404-3069, USA

Report Reference: E84967, March 17, 1992

**This is to Certify that
representative samples of:** Molded Case Circuit Breakers
Type HOM Series 1

Have been investigated by Underwriters Laboratories Inc. in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 489, Molded Case Circuit Breakers and Circuit
Breaker Enclosures

Additional Information: These are two pole circuit breakers, rated from 80A through
100A.
Current Interrupting Rating is as follows:
10,000A, 120/240 Vac, 1phase, 50/60 Hz.
Uses wires rated as follows:
75 Deg. C only.

**Only those products bearing the UL Listing Mark should be considered as being covered by UL's
Listing and Follow-Up Service.**

The UL Listing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" (UL); the word "Listed"; a control number (may be alphanumeric) assigned by UL; and the product or category name (product identifier), as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: *Lawrence Smith*
Underwriters Laboratories Inc.

Lawrence Smith

Review Engineer: *Jeffrey Hidaka*
Underwriters Laboratories Inc.

Jeffrey Hidaka